

City Council Recap: May 21, 2024, page 1 of 2

Agenda at <https://pendleton.or.us/meetings>

Action key:



Approved



Failed/Denied



Tabled/Modified

Community Discussion:

- ◆ *Ed Miltenberger spoke about designated loading zones in front of his business.*

Consent Agenda: *The consent agenda groups routine meeting actions into a single agenda item so they can be approved in one step, rather than in multiple motions.*

- ✓ *Minutes of the May 7, 2024, City Council meeting; announcement of executive session to discuss real property and the city manager evaluation.*

Old Business Revisited

- ✗ *Bid Award: NW Despain Avenue Reconstruction & Waterline: The council voted to reopen discussion about the bid award to reconstruct seven blocks of NW Despain Avenue. Multiple people spoke about the project. At the May 7 meeting, council voted 5-3 to authorize a bid for the reconstruction; however, some area residents complained about the inclusion of bulb-outs on the south side of the street. The council voted on a motion to rebuild the street without bulb-outs on the south side. At a 4-4 split vote, Mayor John Turner voted to break the tie, and the reconstruction will continue with bulb-outs as bid.*

Bids

- ✓ *Chemical Captor and PAX14 Purchase for RRF: The Captor is the chemical that removes residual chlorine from processed water before being discharged into the Umatilla River, and Pax 14 is used by the RRF Staff to manage and control filamentous bacteria in the Aeration basin. A purchase order was approved to Cascade Columbia for \$82,221.*
- ✓ *Polymer chemical purchase for Wastewater Treatment Resource Recovery Facility (WWTRRF): Polymer is the first stage of separating digested liquid from solids. A purchase order was approved to Polydyne Inc. in the amount of \$66,240.00*




Continued on page 2

City Council Recap: May 21, 2024, page 2 of 2

Agenda at <https://pendleton.or.us/meetings>

Action key:



Approved




Failed/Denied





Tabled/Modified

Continued from Page 1

Bids

-  Purchase of disinfection chemical (sodium hypochlorite) for the WWT/RRF: A purchase order was approved to HASA in the amount of \$59,020.00.

New Business

- ◆ Annual Tree Commission Report
-  Anderson Perry, Work Order 2024-1 SE 11th Street Shovel Ready Design: *The City of Pendleton plans to extend SE 11th Street from SE Franklin Grade Road to the end of the current right of way. This design would make the project “shovel ready.” The work order is not-to-exceed \$90,500.*
-  Consor North America: Task Order No. 30: Water System Master Plan Projects: M-1 & M-47 Alternative: *The Water System Master Plan called for two new waterline looping projects to prevent water pressure drops during operation of the Aquifer Storage and Recovery Program. One water line, M-1, will be a least 790 lineal feet and drills under the Umatilla River; the second water line, M-47, is about 1,450 lineal feet and drills under a rail spur line and UPRR main line. Construction is planned ofr summer and fall 2025 with an estimated construction cost of \$3 million. River This task order authorizes Consor to complete design and predesign work for that project for up to \$587,359.*

Meeting adjourned to executive session at 8:18 p.m.

Next meeting — 7 p.m., June 4

What more information? To access City Council agendas and minutes, visit www.pendleton.or.us and click the button marked “meetings.”