

ADDENDUM NO. 3

To the Contract Documents

City of Pendleton, Oregon Wastewater Treatment Plant Clarifier Rehabilitation - 2024

June 21, 2024

Bid Date: July 2, 2024
Bid Closing: 2:00 p.m.
Bid Opening: 2:00 p.m.
Disclosure Deadline: 4:00 p.m.

The following additions, deletions, and modifications shall be made to the Bid Schedule and the Contract Documents.



I. BID SCHEDULE

Delete the Bid Schedule in its entirety and replace it with the attached Bid Schedule - REVISED.

(Note: The Unit designation for Bid Items 5 and 6 changed from S.Y. to S.F.)

II. CONTRACT DOCUMENTS

A. GENERAL REQUIREMENTS

- 1. A. SUMMARY OF WORK, page GR-1.** Add the following sentence to the end of this paragraph:

All equipment required for the Work shall be supplied by the Contractor and in accordance with the Technical Specifications.

2. **E. BYPASS PUMPING, page GR-5.** Delete the last two sentences of the first paragraph in their entirety and replace them with the following:

It is anticipated that the bypass pumps will be required to pump up to 1,400 gpm at 75 ft of head, and the bypass pumping systems may be required to operate 24 hours per day. Connection to the existing RAS station external bypass pumping ports may be facilitated via two 2-inch threaded connections. The Contractor may also elect to supply and utilize approximately 200 feet of temporary discharge piping to discharge to the Plant Pump Station.

B. TECHNICAL SPECIFICATIONS

1. **SECTION 10 - MEASUREMENT AND PAYMENT, PART 1 - GENERAL, 1.3 Payment Items, B. Method of Payment, 5., page 10-4.** Delete the first two sentences of the first paragraph in their entirety and replace them with the following:

Measurement for payment shall be on a square foot basis for these bid items. Area in square feet shall be computed as the length along centerline of pipe times the allowable pay width of surface restoration.

III. DRAWINGS

- A. SHEET D-301, DEMOLITION SECTION.** Add the following note 7:

The existing bridge weight is estimated to be approximately 12,000 pounds, excluding the center pier. It is anticipated that all other components to be removed can be disassembled to component parts whose individual weights are less than the weight of the bridge.

- B. SHEET M-502, SLIDE GATE DETAIL.** Add the following note for the Secondary Effluent Combiner Box Slide Gate Detail:

Contractor shall field-verify the total height of the existing secondary effluent combiner box to provide slide gate height as required for the gate handwheel to be just above the top of wall as shown. Based on Record Drawings, the height is estimated to be approximately 12.5 feet.

- END OF ADDENDUM NO. 3 -

**CITY OF PENDLETON, OREGON
 SECONDARY CLARIFIER REHABILITATION
 BID SCHEDULE - REVISED
 JUNE 2024**

NO.	ITEM	UNIT	UNIT PRICE	AMOUNT	TOTAL PRICE
1.	Mobilization/Demobilization	L.S.	XXX	All Req'd	_____
2.	Demolition/Salvage	L.S.	XXX	All Req'd	_____
3.	Repair of Unmarked Sewer	EA	_____	2	_____
4.	Repair of Unmarked Utility	EA	_____	2	_____
5.	Gravel Surface Restoration	S.F.	_____	750	_____
6.	Asphalt Surface Restoration	S.F.	_____	580	_____
7.	Northern Concrete Curb	L.F.	_____	245	_____
8.	2-inch Non-potable Water Line	L.S.	XXX	All Req'd	_____
9.	Return Activated Sludge Pump Station Slide Gate Installation	L.S.	XXX	All Req'd	_____
10.	Secondary Effluent Combiner Box Slide Gate Installation	L.S.	XXX	All Req'd	_____
11.	Secondary Clarifier Rehabilitation and Equipment Installation	L.S.	XXX	All Req'd	_____
12.	Bypass Pumping	L.S.	XXX	All Req'd	_____
13.	Secondary Clarifier Floor Relief Valve Installation	EA	_____	8	_____
14.	Secondary Clarifier Launder Coating	L.S.	XXX	All Req'd	_____
15.	Electrical and Controls	L.S.	XXX	All Req'd	_____
				Total Base Bid	\$ _____
Additive Alternative					
1.	Southern Concrete Curb	L.F.	_____	245	_____
				Total Additive Alternative	\$ _____
				TOTAL BASE BID PLUS ADDITIVE ALTERNATIVE	\$ _____