

ADDENDUM NO. 5

To the Contract Documents

City of Pendleton, Oregon
Wastewater Treatment Plant Clarifier Rehabilitation - 2024

June 27, 2024

Bid Date: July 2, 2024
Bid Closing: 2:00 p.m.
Bid Opening: 2:00 p.m.
Disclosure Deadline: 4:00 p.m.

The following additions, deletions, and modifications shall be made to the Contract Documents.



RENEWS 12-31-24

I. CONTRACT DOCUMENTS

A. TECHNICAL SPECIFICATIONS

1. **SECTION 5 - SECONDARY CLARIFIER IMPROVEMENTS, PART 2 - MATERIALS, 2.4 Drive Mechanism, B. Physical Characteristics, 2. Intermediate Reduction Unit, page 5-8.** Delete the second paragraph in its entirety and replace it with the following:

The main gear to pinion gear mesh shall be oil or grease lubricated per the manufacturer's standard design. Lubrication fittings shall be readily accessible.

- END OF ADDENDUM NO. 5 -